Govt. of Jammu & Kashmir

KASHMIR PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Testing Laboratory Public Health Engineering Division Sopore

Land mark: Iqbal Market Sopore.

nple Analysed at: WTL watlab
o. Ref no. PHE/WSS nagbug. Habitation:- Army Goodwill School nagbug.

Date of Examination: 31-10-26
Concerned Sub Div: watlab

REPORT

Jo	Parameters	Unit	Permissible limit	Result
	Iron.	Mg/l	0.3-1.00	0.00
	Nitrate	Mg/l	45.0-45.0	0.00
	Arsenic	Mg/l	0.01-0.01	0.00
	Fluorides	Mg/l	1.0-1.5	0.5
	Chloride	Mg/l	250-1000	50.00
	Bacteriological	MPN	0.00-0.00	Absent
	TDS	Mg/l	500-2000	270.00
	Alkalinity	Mg/l	200-600	60.00
	calcium	Mg/l	75-200	40.00
	Aluminum	Mg/l	0.2-0.3	0.00
	Copper	Mg/l	0.05-1.5	0.00
	Magnesium	Mg/l	30-100	0.00
	Residual Chlorine	Mg/l	0.2-1.0	0.1
	Sulphate	Mg/l	200-400	70.00
	Manganese	Mg/l	0.1-0.3	0.00
	P.H		6.5-8.5	7.6
	Turbidity	NTU	1.0-5.0	2.03
	Hardness	Mg/l	200-600	105.00

Principal Army Goodwill School Sopore

Impression:- As per above Tested parameters this water is fit for drinking

Lab Assistant

Chemist

Government of Jammu & Kashmir (UT)
JAL SHAKTI DEPARTMENT (P.H.E)
OFFICE OF THE EXECUTIVE ENGINEER PHE DIVISION
SOPORE

Land Mark Iqbal Market Sopore Phone No/Fax: 01954 - 222482 E.Mail: phesopore@gmail.com

The Principal,
Army Goodwill School.
Mazbugh Sopore.

No: JS/PHE/SPR/1443-44
Dated:- 02-06-2026

Sub:- Issuance of Drinking water and Sanitary Condition Certificate

Ref:- Your ℓ letter No. 820-AGS-26, dated:12-05-2026.

Sir,

With reference to your above quoted letter regarding the issuance of drinking water and sanitary condition certificate, it is to certify that adequate drinking water facilities and satisfactory sanitary conditions are available in the premises of Army Goodwill School Mazbugh Sopore as reported by the Assistant Executive Engineer PHE Sub Division Watlab vide his No. SDW 104, dated:21-05-2026. The facilities were found functional, hygienic and properly maintained at the time of inspection.

Yours faithfully

02.06.26

Executive Engineer
Jal Shakti (PHE) Division
Sopore

Copy to the:

1. Assistant Executive Engineer PHE Sub Division Watlab for information.