Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar

The Principal,
Army Goodwill School,
Mazbugh Sopore District Baramulla.

No: DFES/FP/9/2023-04/CC-7079422-**10593** Dated. 18 :05:2026.

Sub: - Fire & life safety measures/ guidelines in favour of "Army Goodwill School" situated at Mazbugh Sopore District Baramulla.

Ref: - Your online submission tracking-Id. F1-62841869 submitted date, 06-05-2026.

The on spot Inspection of above said school was got carried out by the Deputy Director F&ES Command Sopore and found that the management has installed 11 unit of ABC type 06 kg, 01 unit of CO2 type 4.5 kg capacity and 02 No's. of water type 09 liters capacity in their school premises. However, the site is 03 Km away from Fire & Emergency Services Station Sopore and is accessible for fire appliance. Since the school is already functioning in 02 double storeyed building and 01 single storeyed prefabricated shed, as such the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there:-

1. 01 unit of water type 09 liters capacity fire extinguishers shall be provided in each floor of the school building, in addition to already existing fire extinguisher.
2. Hose Reel shall be installed in double storeyed building connected with dedicated terrace tank of 10,000 Lt. capacity and shall be kept at such a place where from every nook and corner of the building are covered easily at the time of an emergency. A Fire Pump of desired capacity having 450 LPM discharge output shall be installed near terrace water storage tank with dual electric supply for feeding the Hose Reel .
3. Wooden components of the structure especially in attic portion shall be given fire retardant treatment of at least two hours rating.
4. All exits/entrances shall be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency. The corridor of the building shall not be used for any kind of storage. Grill fitted on the windows shall be removed.
5. No Hazardous material shall be kept inside of the school premises (especially LPG cylinder, Petrol, Diesel and Central Heating System etc.) Any deviation found in this regard, these fire and life safety measures/guidelines issued will be treated automatically withdrawn/cancelled.
6. The Management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
7. Class/Halls have a capacity of more than 45 students shall have two exits. Fire/Evacuation drill shall be conducted regularly. Employees of the school shall be trained for maintenance & use of Fire Fighting facilities.
8. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, these fire and life safety measures/ guidelines issued shall be treated automatically withdrawn/cancelled.
9. At present school is functioning in three structures, As such no addition/ alteration shall be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, these fire and life safety measures/ guidelines will be treated automatically withdrawn/ cancelled.
10. Additional staircase shall be provided in Block B building.
11. The students of preschool, kindergarten, up to class 1st shall be accommodated on ground floor and class 2nd students shall be accommodated not above 1st floor of the building.
12. **These fire & life safety measures/guidelines shall be subject to outcome of any dispute/investigation enquiry/trial if any pending before any court of Law/investigation agency. These fire & life safety measures/guidelines shall not confirm any title upon the person/company in whose favour it is issued. Furthermore the status with regards to land shall be the responsibility of the concerned registering authority.**
13. **The instant fire safety measures is strictly for adoption of fire safety recommendations/guidelines of the occupancy only and not for authentication of any other claim.**
14. **While issuing final registration /permission to above said establishment, the authority concerned may ensure the fire safety recommendation/guidelines given to the school by this department are fully complied with.**
15. **These fire & life safety measures/guidelines are issued in respect of the institution with a validity of one year for adoption & same needs to be renew after inspection/checking of entire fire fighting system installed in the school (i:e existing as well as proposed by the technical officer of this department. However, before granting permission/recognition/extension or renewal thereof, the competent authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 & SRO-292 of 2018 , issued by Education Department with regard to Physical facilities.**

18/05/2026

Director,
Fire & Emergency Services, J&K,
Jammu/Srinagar.